



Leak Detection Test Reporting Requirements for OPW ATG Static Leak Detection

(all models except Site Sentinel)

BUREAU OF WEIGHTS & MEASURES

PO Box 8911

Madison, WI 53708

608-224-4942

datcpweightsandmeasures

@wisconsin.gov

www.datcp.wi.gov

RESOURCES

More information on
applicable Wisconsin laws
can be found at these links:

Wis. Admin. Code § ATCP 93.510

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510

Wis. Admin Code § ATCP 93.515

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515

Materials Approval Page

https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx

OPW

<http://www.opwglobal.com/>

Approval #20080009

<https://datcp.wi.gov/Documents/ER-BST-MA-20080009.pdf>

When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with passing test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is a static test report example that your OPW ATG system (except the Site Sentinel) will print. You are required to submit the test report when renewing your annual permit to operate.

LAST PASSED
TLM STATIC TEST :

TANK 1 DIESEL

0.1 GPH TEST
07-28-15 06:11:00
PRODUCT LEVEL 64.28 "
% VOLUME 54 %
TEMPERATURE 66.84 F
CALCULATED RATE OF
CHANGE : -0.018
(VOLUME IS INCREASING .)

0.2 GPH TEST
07-28-15 06:11:00
PRODUCT LEVEL 64.28 "
% VOLUME 54 %
TEMPERATURE 66.84 F
CALCULATED RATE OF
CHANGE : -0.018
(VOLUME IS INCREASING .)

If you have questions about how your OPW ATG system works please contact your service company or [OPW](#) directly. You can also find further information about your specific leak detection equipment on the materials approval page of our [website](#). The OPW material approval number is [20080009](#).

(over)

Leak detection FAQs:

- *What is leak detection?*
“Leak Detection” means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.
- *What is “ATG”?*
“Automatic Tank Gauging” (ATG) or “Automatic Leak Detection” means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.
- *What is static testing?*
[Wisconsin Administrative Code §§ ATCP 93.510](#) and [93.515](#) require all new and existing underground tank systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is “static” leak detection testing.

A static test monitors the integrity of the tank system by measuring changes in product volume/level. This type of test may require the tank system to be shut down for several hours, during which time there should be no dispensing or delivery of product. The test must be performed with a minimum amount of product as determined by the manufacturer of the system

Rev. 11/16/16